

No	Activity	Hazard	Person(s) in Danger	Control Measures	Residual Risk Rating
37	All activities involving the electric operations	<b>Working with Electricity</b>  Potential for electrocution, fire, and explosion	Employees, other contractors and public	<ul style="list-style-type: none"> <li>- Operatives shall be trained and have been appointed at the relevant competency level by the Network Operators to carry out the task.</li> <li>- Operatives must adhere to MTS and the Network Operators electrical safety rules.</li> <li>- Operatives shall assess electrical risks and hazards and plan their actions. Any live apparatus shall be screened.</li> <li>- Where appropriate locks and isolation tags must be applied.</li> </ul> <p><b>Low Voltage Work</b></p> <ul style="list-style-type: none"> <li>- The preferred option is to work dead. Justification must be recorded before any live work is carried out.</li> <li>- Approved procedures must be available to undertake live work and operatives fully trained.</li> <li>- Faulty apparatus / cables shall not be worked on live.</li> </ul> <p><b>High Voltage Work</b></p> <ul style="list-style-type: none"> <li>- Operatives must be in possession of an approved Safety Document before carrying out any work.</li> </ul>	Low

				<b>Switching / Linking</b> <ul style="list-style-type: none"> <li>- Operatives shall be authorised and trained.</li> </ul>	
--	--	--	--	--	--