

No	Activity	Hazard	Person(s) in Danger	Control Measures	Residual Risk Rating
22	Any activity that involves working at height	Work at Height Falling from height	Employees other contractors and public	 Where possible avoid working at heights. E.g. pre-assemble structures on the ground or use extendible equipment where possible. If unavoidable: Use access towers, mobile elevated working platforms by competent personnel (MEWP's), guardrails and toe boards (where appropriate). Ladders will only be used for access and for short duration, low risk work. An excavation is classed as Working from Height. Wear appropriate PPE and personal fall arrest and equipment will be considered but as a last resort. Use appropriate harnesses, life lines and lanyards. 	Low