

No	Activity	Hazard	Person(s) in Danger	Control Measures	Residual Risk Rating
26	Use of Flammable Liquids	<p>Flammable Liquids</p> <p>Potential for release of vapours / liquids hazardous to health and risk of ignition of liquid / vapour</p>	Employees, other contractors and public	<ul style="list-style-type: none"> - Keep the lid tightly on containers when not in use. - Do not use any equipment that generates heat or sparks (including electrical sparks) in the area in which these products are stored or used. - Only keep sufficient quantities at the place of work to carry out the immediate job in hand – otherwise, store surplus quantities in the proper store provided. - Do not smoke in the area that these products are stored or used. - Wherever possible, use in well-ventilated areas – otherwise respiratory protective equipment (e.g. filter type respirator) may have to be worn. - Always follow the manufacturer's instructions. Clear up spillages immediately and safely dispose of contaminated cleaning materials. - If a spillage is within a building, open doors and windows if appropriate. In order to help ventilation - Appropriate fire extinguishers to be available. 	Low

				- Report all spillages to the Morrison Incident Line.	
--	--	--	--	---	--