




WALLS B & D
(SIDE WALLS)



WALL C
(END WALL)



WALL A
(END WALL)



PLAN

NOTES

1. THIS DRAWING TO BE READ IN CONJUNCTION WITH ALL OTHER DRAWINGS, DOCUMENTATION AND SPECIFICATIONS RELATING TO THIS MANHOLE STRUCTURE TYPE CONSTRUCTION
2. REINFORCEMENT TO BE GRADE B500B OR B500C CONFORMING TO BS4449: 2005 (REFER CLAUSE 1712 SHW).
3. BAR SCHEDULE AND BENDING TO CONFORM TO BS8666.
4. MINIMUM COVER 55mm TO ANY CONCRETE FACE PROPRIETARY APPROVED SPACERS TO BE UTILISED.
5. BARS INTERSECTING HOLES TO BE CUT ON SITE AND TRIMMED TO CN13916
6. ADDITIONAL BARS MAY BE UTILISED TO TIE / SUPPORT MAIN BARS AS REQUIRED.
7. MAX BAR SPACING TO BE 150mm.

(END WALL)

| | | | | | | | | | | |
|--|-------------------------|--|-------------------|--|-------|--|---|---------------------|---|----------|
| DIMENSIONS IN mm UNLESS OTHERWISE STATED | | | | © British Telecommunications plc 1994 | | DO NOT SCALE | | ORIGINAL SCALE 1:20 | | |
| A1 A2 | DRN RFG C S CKD M.S. | ANY MODIFICATION TO THE DRAWING OR THE USE OF ALTERNATIVE ITEMS TO THOSE SPECIFIED <u>MUST</u> BE AGREED WITH THE DESIGNER. | MATERIAL - | OMS Drawing Review Drawing number amended to 03 of 08 | E | TOLERANCES TO SPECS BS8666, BS5606, BS EN1992 CN15456. | STANDARD MANHOLE MRX611A,611B,611C WALL REINFORCEMENT | | REFERENCES SPECS: BS8666, BS EN1992 DRGS: CN15456. | |
| | FINISH - | | VARIOUS LOCATIONS | | | | | | | |
| | DATE 04/07/94 | | | BT | OMS | 25.08.15 | Openreach | | ALA944 | CN 14947 |
| | | | AMENDMENT | | ISSUE | | | | | |