

No	Activity	Hazard	Person(s) in Danger	Control Measures	Residual Risk Rating
62	Working within restricted spaces	<b>Asphyxiation</b>  Slips, Trips, Falls, Heat / Exhaustion, Lone Working	Employees, Other Contractors	<ul style="list-style-type: none"> <li>- Dynamic risk assessment prior to entry.</li> <li>- Ensure suitable and clear access and egress routes at present at all times.</li> <li>- Remove any obstructions.</li> <li>- Ensure suitable lighting is present.</li> <li>- Ensure suitable ventilation is available.</li> <li>- Mobile phone is available and can be used.</li> <li>- Occupier is made aware of how long you will be in the space.</li> <li>- Be aware of sharps and odours.</li> <li>- Consider two (2) persons working based on risk assessment.</li> </ul>	Low