

No	Activity	Hazard	Person(s) in Danger	Control Measures	Residual Risk Rating
13	Work in the public highway	Street Works  Failure to adequately notify and protect the work area and activity from vehicles and pedestrians	Employees, other contractors and public	<ul> <li>At least one member of your team must be in possession of a current valid New Road Works and Street Works (NRWSA) operator's training card.</li> <li>You must carry and adhere to the current Code of Practice (Red Book) and refer to it when setting up your site.</li> <li>When completing an on-site specific risk assessment, additional hazards must be identified and recorded. E.g. schools, pubs, shops, hospitals etc.</li> <li>Adequate pedestrian access should be maintained at all times.</li> <li>Heras fencing and warning signs must be erected for deep excavations and sensitive areas. (e.g. Play Areas, Shopping Centres etc.)</li> <li>Hi visibility clothing to be worn at all times.</li> </ul>	Low

Generic Risk Assessments for work on or around the