



- NOTES
- THIS DRAWING TO BE READ IN CONJUNCTION WITH ALL OTHER DRAWINGS, DOCUMENTATION AND SPECIFICATIONS RELATING TO THIS MANHOLE STRUCTURE TYPE CONSTRUCTION
 - REINFORCEMENT TO BE GRADE B500B OR B500C CONFORMING TO BS4449 (REFER CLAUSE 1712 SHW).
 - BAR SCHEDULE AND BENDING TO CONFORM TO BS8666.
 - MINIMUM COVER 55mm TO ANY CONCRETE FACE PROPRIETARY APPROVED SPACERS TO BE UTILISED.
 - BARS INTERSECTING HOLES TO BE CUT ON SITE AND TRIMMED TO CN13916
 - ADDITIONAL BARS MAY BE UTILISED TO TIE / SUPPORT MAIN BARS AS REQUIRED.
 - MAX BAR SPACING TO BE 150mm c/c.
- BAR NOTATION
- No. OF BARS 7 B 12 04 150
- TYPE OF STEEL
- DIA OF BARS
- BAR MARK
- SPACING
- BAR LOCATION
- FAR FACE OUTER LAYER - F1
 - FAR FACE SECOND LAYER - F2
 - NEAR FACE OUTER LAYER - N1
 - NEAR FACE SECOND LAYER - N2
 - BOTTOM FACE OUTER LAYER - B1
 - BOTTOM FACE SECOND LAYER - B2
 - TOP FACE OUTER LAYER - T1
 - TOP FACE SECOND LAYER - T2