


FLOOR PLAN

Chamfer Bar (28) omitted for clarity from floor & roof plan



ROOF PLAN

NOTES


1. THIS DRAWING TO BE READ IN CONJUNCTION WITH ALL OTHER DRAWINGS, DOCUMENTATION AND SPECIFICATIONS RELATING TO THIS MANHOLE STRUCTURE TYPE CONSTRUCTION
2. REINFORCEMENT TO BE GRADE B500B OR B500C CONFORMING TO BS4449: 2005 (REFER CLAUSE 1712 SHW).
3. BAR SCHEDULE AND BENDING TO CONFORM TO BS8666.
4. MINIMUM COVER 55mm TO ANY CONCRETE FACE PROPRIETARY APPROVED SPACERS TO BE UTILISED.
5. BARS INTERSECTING HOLES TO BE CUT ON SITE AND TRIMMED TO CN13916
6. ADDITIONAL BARS MAY BE UTILISED TO TIE / SUPPORT MAIN BARS AS REQUIRED.
7. MAX BAR SPACING TO BE 150mm c/c.

BAR NOTATION


| | | | | | |
|---------------|---|---|----|----|-----|
| | 7 | B | 12 | 04 | 150 |
| No. OF BARS | | | | | |
| TYPE OF STEEL | | | | | |
| DIA OF BARS | | | | | |
| BAR MARK | | | | | |
| SPACING | | | | | |

BAR LOCATION

| | | |
|--------------------------|---|----|
| FAR FACE OUTER LAYER | - | F1 |
| FAR FACE SECOND LAYER | - | F2 |
| NEAR FACE OUTER LAYER | - | N1 |
| NEAR FACE SECOND LAYER | - | N2 |
| BOTTOM FACE OUTER LAYER | - | B1 |
| BOTTOM FACE SECOND LAYER | - | B2 |
| TOP FACE OUTER LAYER | - | T1 |
| TOP FACE SECOND LAYER | - | T2 |



WALLS B & D
(SIDE WALLS)



WALLS A & C
(END WALLS)

MANHOLE DRAWN TO 'C' SIZE

DIMENSIONS IN mm UNLESS OTHERWISE STATED

© British Telecommunications plc 1994

DO NOT SCALE

ORIGINAL SCALE 1:20

| | | | | | | | | | | | | |
|----------|--|--|----------|--|----------|--|---|-------|--|--------|----------|--------------|
| A1 A2 | DRN RFG C S | ANY MODIFICATION TO THE DRAWING OR THE USE OF ALTERNATIVE ITEMS TO THOSE SPECIFIED MUST BE AGREED WITH THE DESIGNER. | MATERIAL | OMS Drawing Review Drawing number amended to 02 of 04 | E | TOLERANCES TO SPECS BS8666, BS5606, BS EN1992 CN15456. | STANDARD MANHOLE MRX 410A,410B,410C ROOF, FLOOR AND WALL REINFORCEMENT | | REFERENCES SPECS: BS8666,BS5606 & BS EN1992 DRGS: CN15456 | | | |
| | CERTIFICATION DESIGNER M DA RIOS | | FINISH | | | VARIOUS LOCATIONS | | | | | | |
| | CLIENT M DA RIOS | | | | | | | | | | | |
| | DATE 04/07/94 | | | | | | | | | | | |
| | | | BT | OMS | 21.08.15 | | | | | | | |
| | | | | | | AMENDMENT | | ISSUE | Openreach | ALA944 | CN 14935 | SHT 02 OF 04 |
| | | | | | | | | | | | | |