



SECTION B-B

1. THIS DRAWING TO BE READ IN CONJUNCTION WITH ALL OTHER DRAWINGS, DOCUMENTATION AND SPECIFICATIONS RELATING TO THIS MANHOLE STRUCTURE TYPE CONSTRUCTION
2. REINFORCEMENT TO BE GRADE B500B OR B500C CONFORMING TO BS4449: 2005 (REFER CLAUSE 1712 SHW).
3. BAR SCHEDULE AND BENDING TO CONFORM TO BS8666.
4. MINIMUM COVER 55mm TO ANY CONCRETE FACE. PROPRIETARY APPROVED SPACERS TO BE UTILISED.
5. BARS INTERSECTING HOLES TO BE CUT ON SITE AND TRIMMED TO CN13916
6. ADDITIONAL BARS MAY BE UTILISED TO TIE / SUPPORT MAIN BARS AS REQUIRED.
7. MAX BAR SPACING TO BE 150mm c/c.


Chamfer bars (28) omitted from plans for clarity
refer to sheet 3 of 4 for spacing



PLAN ON FLOOR



SECTION D-D



SECTION C-C

SPACING

TOP FACE SECOND LAYER

- F1
- F2
- N1
- N2
- B1
- B2
- T1
- T2

ORIGINAL SCALE 1:20

SHT 02 OF 04

4