

No	Activity	Hazard	Person(s) in Danger	Control Measures	Residual Risk Rating
24	Use of electrical equipment	<b>Electrical Equipment</b>  Electrical shock and burns	Employees, other contractors and public	<p>Electrical equipment “electric power tools should be regularly inspected and maintained by a competent electrician” power tools should be, inspected by the user each time they are used and portable appliance test (PAT) in accordance with company policy and a record kept and recorded on the electrical item. Electrical Tools should only be maintained by an appointed competent person, who maybe an electrician.</p> <ul style="list-style-type: none"> <li>- Use tools on correct power supply as instructed on the maker’s label.</li> <li>- Only use 110 volt and battery powered equipment. Never use 240 volt equipment.</li> <li>- Portable electric tools should only be used for their designated purpose only.</li> <li>- Avoid use of extension leads where possible.</li> <li>- Disconnect from power source when not in use.</li> <li>- Wear appropriate eye protection with regard to possible impact damage if there is any risk to the eyes.</li> </ul>	Low

				<ul style="list-style-type: none"> <li>- Eye protection, respiratory protection and overalls to be worn when using battery packs.</li> </ul>	
--	--	--	--	--	--