


9B20-02A-150T1 12B20-01A-150T2 12B20-01A-150T2

> FLOOR PLAN (UPPER LAYERS)

FLOOR PLAN (LOWER LAYERS)

<u>NOTES</u>

- 1. THIS DRAWING TO BE READ IN CONJUNCTION WITH ALL OTHER DRAWINGS, DOCUMENTATION AND SPECIFICATIONS RELATING TO THIS MANHOLE STRUCTURE TYPE CONSTRUCTION
- 2. REINFORCEMENT TO BE GRADE B500B OR B500C CONFORMING TO BS4449: 2005 (REFER CLAUSE 1712 SHW).
- 3. BAR SCHEDULE AND BENDING TO CONFORM TO BS8666.
- 4. MINIMUM COVER 55mm TO ANY CONCRETE FACE PROPRIETARY APPROVED SPACERS TO BE UTILISED.
- 5. BARS INTERSECTING HOLES TO BE CUT ON SITE AND TRIMMED TO CN13916
- 6. ADDITIONAL BARS MAY BE UTILISED TO TIE / SUPPORT MAIN BARS AS REQUIRED.
- 7. MAX BAR SPACING TO BE 150mm.



DIMENSIONS IN mm UNLESS OTHERWISE STATED © British Telecommunications plc 1994 DO NOT SCALE ORIGINAL SCALE 1:20 DRN RFG C S TOLERANCES TO SPECS MATERIAL OMS Drawing Review REFERENCES STANDARD ANY MODIFICATION TO THE DRAWING SPECS: BS8666, BS8666, BS5606, BS EN1992 CN15456. Drawing number amended to 02 of 08 OR THE USE OF ALTERNATIVE MANHOLE MRX513a,513b,513c CKD M.S. $\frac{A1}{A2}$ BS EN1992 BE AGREED WITH THE DESIGNER. CERTIFICATION DRGS: CN15456. FLOOR REINFORCEMENT M DA RIOS **FINISH** VARIOUS LOCATIONS 24.08.15 OMS M DA RIOS SHT 02 OF 08 CN 14943 ALA944 ISSUE Openreach DATE 04/07/94 **AMENDMENT**