




PLAN GENERAL ARRANGEMENT




SECTION A-A



SECTION C-C



SECTION D-D



DUCT SETTING OUT

- NOTES
- FOR TYPICAL DETAILS SEE DRAWING CN15647 SHEET 01.
 - ALL DIMENSIONS IN MILLIMETRES
 - ALL EXISTING SERVICE POSITIONS ARE TO BE VERIFIED ON SITE BY THE CONTRACTOR PRIOR TO STARTING THE WORKS.
 - ALL ACCEPTED SAFE DIGGING PRACTICES AND METHODS OF WORKING ARE TO BE EMPLOYED DURING THE INSTALLATION OF THE STRUCTURE.
 - ALL WORKS TO BE UNDERTAKEN IN ACCORDANCE WITH THE SPECIFICATION FOR HIGHWAY WORKS (SHW) AND ALL SUBSEQUENT AMENDMENTS.
 - ALL BACKFILL MATERIALS TO BE CLASS 6N TYPE.
 - CONTRACTOR TO PROVIDE A GENERAL ARRANGEMENT DRAWING SHOWING THE POSITION OF THE STRUCTURE IN RELATION TO THE HIGHWAY AND ITS FEATURES.
 - ALL DUCTS TO BE USED FOR ELECTRICAL SUPPLY, TO BE LAID AT 450mm DoC TO FOLLOW NJUG RECOMMENDATIONS.
 - ALL DUCTS TO BE USED FOR ELECTRICAL SUPPLY TO BE EITHER BLACK OR RED TO FOLLOW NJUG RECOMMENDATIONS. PREFERENCE AS PER LOCAL POWER SUPPLIER REQUIREMENTS.
 - CONDUCTIVE CONCRETE TO BE INSTALLED AND A READING OF NO GREATER THAN 20 OHMS OBTAINED, PRIOR TO INSTALLATION OF CABINET PLINTH. (REFER TO ISIS EPT/ANS/A055 - FTTC EARTHING MANUAL).
 - WHEN LOCATING, ENSURE 1.0 METRE CLEAR SPACE FOR POWER DOOR OPENING.
 - PLINTH SURFACE TO BE LEVEL IN BOTH WIDTH AND LENGTH.

DIMENSIONS IN mm UNLESS OTHERWISE STATED												© British Telecommunications plc 2010		DO NOT SCALE		ORIGINAL SCALE 1:5	
A1 A2	DRN TPS(CONTRACTOR) CKD DC		ANY MODIFICATION TO THE DRAWING OR THE USE OF ALTERNATIVE ITEMS TO THOSE SPECIFIED MUST BE AGREED WITH THE DESIGNER.	MATERIAL		CAB AMENDED TO INCLUDE CONDUCTIVE CONCRETE		I	FTTC 288 STAND ALONE CABINET PRE-CAST CONCRETE PLINTH ON CONDUCTIVE CONCRETE		REFERENCES SPEC LN550						
	CERTIFICATION DESIGNER DC			FINISH													
	CLIENT CARILLION TELENT			RS 05/11/20													
DATE 09/07/2010					AMENDMENT		ISSUE	OPENREACH		BEA 3	CN 15647	SHT 4 OF 9					