



Notes.

1. END DUCTS TO BE IN LINE
2. WHERE POSSIBLE DUCTS TO BE POSITIONED NO LESS THAN 75MM FROM SIDE WALLS & 100MM FROM BASE
3. CHAMBER SIDE WALLS TO BE BACK FILLED MINIMUM 150MM COMPACTED TYPE 1 MOT

<div> <b>CUBIS</b> SYSTEMS A CRH COMPANY</div>	Copyright of Cubis. No part of this document may be communicated, copied or used without prior permission of Cubis.  www.Cubis-Systems.com		Date	07/09/18	Third Angle Projection		Material			TITLE Gicaclear Footway 6 Fortress Chamber & AX-S Cover - Concrete Plinth				.	--/--/--	.	.
			Drawn	CH			Finish	Galv to EN 1461	DIMS	SIZE A3	DWG NO 16652 - 03	SHEET 1 OF 1	REV .	.	--/--/--	.	.
			Appr.	CH	Weight . kg	Tolerance unless Otherwise Stated +1,-1	mm	Rev	Date					Revision History: Description		Drwn	Appr