JOB TITLE			ITEM Structural Calculations		
DESIGNED- MM	DATE	CHECKED- MM	JOB NO. 0	SHEET 1	REV

Span = 1.0 m

Effective length = 1.20 m

Allowable Deflection = 2.78 mm

Loading Type	**Magnitude (kN/m^2 or kN)**	**Distance (m)**	**Point Loading (kN)**	**Factored Point Loading (kN)**	**Total Loading (kN/m)**	**Factored Loading (kN/m)**
Self-weight	0.40	1.00	-	-	0.40	0.56
Total	-	-	0.00	0.00	0.00	0.00



Maximum Factored Moment = 0.00 kNm

Minimum Second Moment of Area required = 0.00 cm^4

Therefore Use Beam : 127x76x13 UB

Moment of Beam Chosen at Effective Length of 1.5m = 18.0 kNm

Second Moment of Area of Beam Chosen = 473 cm^4

Left Unfactored Reaction = 0.00 kN

Right Unfactored Reaction = 0.00 kN