UUT Report

Station ID:	IT-W-7303101
Serial Number:	NONE
Date:	mercoledì 22 novembre 2023
Time:	09:14:16
Operator:	administrator
Execution Time:	47.0170796 seconds
Number of Results:	138
UUT Result:	**Failed**
Product:	MOD LV
Product type:	MOD LV
Comm type:	COMM1_RS485
Product FW Version:	56010809
Comm FW Version:	56010000
Failure Chain:	

Step	Sequence	Sequence File
Check Outputs	Switch3 - active/no active	FMEA.seq
Switch3 - active/no active	MainSequence	FMEA.seq

Begin Sequence: MainSequence
(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\MOD\FMEA.seq)

Close command and Switch1 closed - Switch2 open - before command	
Status:	Skipped

Open command and Switch1 open - Switch2 closed - before command	
Status:	Skipped

Close command and switches open - during command	
Status:	Skipped

Close command and switches closed - during command	
Status:	Skipped

Open command and switches closed	
Status:	Skipped

Open command and switches open	
Status:	Skipped

TRIP true	
Status:	Skipped

Initial state closed	
Status:	Skipped

TRIP both switches open	
Status:	Skipped

Initial state closed	
Status:	Skipped

TRIP both switches closed	
Status:	Skipped

Initial state closed	
Status:	Skipped

TRIP - Switch1 open - Switch2 closed	
Status:	Skipped

Initial state closed	
Status:	Skipped

Switch3 - active/no active	
Status:	Failed
Module Time:	44.2311844

Begin Sequence: Switch3 - active/no active
(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\MOD\FMEA.seq)

Closed - Open - Active - ON - LOG	
Status:	Done
Switch 1:	True
Swtich 2:	False
Switch 3:	True
Comm Open LOG	
Status:	Done
Open - Closed - NOActive - ON - LOG	
Status:	Done
Switch 1:	False
Swtich 2:	True
Switch 3:	False
Check Outputs	
Status:	Failed
Configuration:	Close command and failure switch 1
Output_1_SIG:	False
Output_2_AUX:	True

Additional Results	
Status:	Done
Configuration:	How is the status of LED?
Fix_Green:	FIX GREEN
Additional Results	
Status:	Done
Configuration:	How is the status of MDP?
Status:	UNLOCKED

Additional Results	
Status:	Done
Configuration:	Additional notes
Status:	''
Open - Closed - Active - ON - LOG	
Status:	Done
Switch 1:	False
Swtich 2:	True
Switch 3:	True
Comm Close LOG	
Status:	Done
Closed - Open - NOActive - ON - LOG	
Status:	Done

Switch 1:	True
Swtich 2:	False
Switch 3:	False

Check Outputs	
Status:	Passed
Configuration:	Close command and failure switch 1
Output_1_SIG:	False
Output_2_AUX:	False

Additional Results	
Status:	Done
Configuration:	How is the status of LED?
Fix_Green:	FIX GREEN

Additional Results	
Status:	Done
Configuration:	How is the status of MDP?
Status:	UNLOCKED

Additional Results	
Status:	Done
Configuration:	Additional notes
Status:	''

Opening maneuvre	
Status:	Skipped

Closed - Open - NoActive - ON - LOG	
Status:	Done
Switch 1:	True
Swtich 2:	False
Switch 3:	False

Comm Open LOG	
Status:	Done

Open - Closed - Active - ON - LOG	
Status:	Done
Switch 1:	False
Swtich 2:	True
Switch 3:	True

Check Outputs	
Status:	Passed
Configuration:	Close command and failure switch 1
Output_1_SIG:	False
Output_2_AUX:	False

Additional Results	
Status:	Done
Configuration:	How is the status of LED?
Blinking_green:	BLINKING GREEN

Additional Results	
Status:	Done
Configuration:	How is the status of MDP?
Status:	UNLOCKED

Additional Results	
Status:	Done
Configuration:	Additional notes
Status:	''

Open - Closed - NoActive - ON - LOG	
Status:	Done
Switch 1:	False
Swtich 2:	True
Switch 3:	False

Comm Close LOG	
Status:	Done

Closed - Open - Active - ON - LOG	
Status:	Done
Switch 1:	True
Swtich 2:	False
Switch 3:	True

Check Outputs	
Status:	Failed
Configuration:	Close command and failure switch 1
Output_1_SIG:	False
Output_2_AUX:	True

Additional Results	
Status:	Done
Configuration:	How is the status of LED?
Blinking_green:	BLINKING GREEN

Additional Results	
Status:	Done
Configuration:	How is the status of MDP?
Status:	UNLOCKED

Additional Results	
Status:	Done
Configuration:	Additional notes
Status:	''

End Sequence: Switch3 - active/no active

RCCB trip - toggle blocked in closed position	
Status:	Skipped

RCCB trip - toggle blocks during open manoeuvre	
Status:	Skipped

Open command - toggle blocks during open manoeuvre	
Status:	Skipped

Open command - toggle blocked in closed position	
Status:	Skipped

Close command - toggle blocks during close manoeuvre	
Status:	Skipped

Close command - toggle blocked in open position	
Status:	Skipped

End Sequence: MainSequence

End UUT Report