

UUT Report

Station ID: IT-W-7303101
Serial Number: NONE
Date: lunedì 6 novembre 2023
Time: 11:15:21
Operator: administrator
Execution Time: 29.4552429 seconds
Number of Results: 162
UUT Result: Terminated
Product: MOD LV
Product type: MOD LV
Comm type: COMM1_RS485
Product FW Version: 56010807
Comm FW Version: 56010000

Begin Sequence: MainSequence
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\General_test.seq)

Simultaneous trip_open	
Status:	Skipped
General and Architecture and LED	
Status:	Skipped
Input-Output	
Status:	Terminated
Module Time:	20.1496965

Begin Sequence: I/O
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\General_test.seq)

Additional Results	
Status:	Skipped
Additional Results	
Status:	Skipped
Additional Results	
Status:	Skipped
Additional Results	
Status:	Skipped
Check Outputs	
Status:	Skipped
Additional Results	
Status:	Skipped
Check Outputs	
Status:	Skipped
Check Outputs	
Status:	Skipped
Check Outputs	
Status:	Skipped

Check Outputs	
Status:	Skipped
Additional Results	
Status:	Done
PopupString:	Check that remote closing worked.
Status:	Passed

End Sequence: I/O

End Sequence: MainSequence

End UUT Report

