UUT Report

Station ID:	IT-W-7303101
Serial Number:	NONE
Date:	**martedì 10 ottobre 2023**
Time:	**15:37:51**
Operator:	**administrator**
Execution Time:	**51.2331329 seconds**
Number of Results:	**28**
UUT Result:	**Failed**
Product:	**ARI LV**
Product type:	**ARI LV**
Comm type:	**COMM1_RS485**
Product FW Version:	**56010804**
Comm FW Version:	**56010000**
Failure Chain:	

Step	Sequence	Sequence File
Check Lock	MainSequence	Blocked MOD.seq

Begin Sequence: MainSequence
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\Blocked MOD.seq)

Check Lock	
Status:	Failed

Additional Results	
Status:	Done
PopupString:	Check that ARI reach Lock state after the default number of reclosing attempts.
Status:	Failed

Additional Results	
Status:	Skipped

End Sequence: MainSequence

End UUT Report