

UUT Report

Station ID: IT-W-7303101
Serial Number: NONE
Date: martedì 7 novembre 2023
Time: 12:06:04
Operator: administrator
Execution Time: 45.4265091 seconds
Number of Results: 90
UUT Result: Passed
Product: MOD HV
Product type: MOD HV
Comm type: COMM1_RS485
Product FW Version: 56010807
Comm FW Version: 56010000

Begin Sequence: MainSequence
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\General_test.seq)

Double_trip_ARI_blocked	
Status:	Skipped
Simultaneous_trip_open	
Status:	Skipped
General and Architecture and LED	
Status:	Skipped
Input-Output	
Status:	Skipped
Power Outage	
Status:	Passed
Module Time:	34.8235284

Begin Sequence: Power Outage
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\General_test.seq)

Additional Results	
Status:	Done
PopupString:	Check that the MOD open automatically the MPD at power On without reclosing.
Status:	Passed
Additional Results	
Status:	Skipped

End Sequence: Power Outage

Motor Driver	
Status:	Skipped

Modbus Register check	
Status:	Skipped
Modbus settings check	

Status:	Skipped
COMM LED & Button	
Status:	Skipped
Firmware Upgrade	
Status:	Skipped

End Sequence: MainSequence

End UUT Report

