

UUT Report

Station ID: IT-W-7303101
Serial Number: L103AB101D
Date: martedì 17 gennaio 2023
Time: 09:32:15
Operator: ITLAVIT1
Execution Time: 00:01:01.944
Number of Results: 71
UUT Result: Passed

Begin Sequence: MainSequence
(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\M4M\PMD-1883.seq)

DUT recap	
Status:	Done
TestResults/Data:	
Serial Number:	L103AB101D
Type Designator:	M4M30SEA
FW Version:	P2.6.14.0
Pulse Output 1 and 2	
Status:	Passed
Module Time:	31.3152

Begin Sequence: Pulse Output 1 and 2
(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\M4M\PMD-1883.seq)

Pass/Fail Test	
Status:	Passed
Pass/Fail Test	
Status:	Passed
Active energy pulses check	
Status:	Passed
Numeric:	82
Limits:	
Low:	78
High:	88
Comparison Type:	GELE(>= <=)
Active energy pulses check	
Status:	Passed
Numeric:	47
Limits:	
Low:	43
High:	53
Comparison Type:	GELE(>= <=)

End Sequence: Pulse Output 1 and 2

Pulse Output 3 and 4	
Status:	Passed
Module Time:	30.5219

Begin Sequence: Pulse Output 3 and 4
(C:\Users\itlavit1\OneDrive -
ABB\LabRnD_Shared\TestStand\Sequences\M4M\PMD-1883.seq)

Pass/Fail Test	
Status:	Passed
Pass/Fail Test	
Status:	Passed
Active energy pulses check	
Status:	Passed
Numeric:	83
Limits:	
Low:	78
High:	88
Comparison Type:	GELE(>= <=)
Active energy pulses check	
Status:	Passed
Numeric:	48
Limits:	
Low:	43
High:	53
Comparison Type:	GELE(>= <=)

End Sequence: Pulse Output 3 and 4

End Sequence: MainSequence

End UUT Report
