

UUT Report

Station ID: IT-W-7303101
Serial Number: NONE
Date: mercoledì 18 ottobre 2023
Time: 16:41:07
Operator: administrator
Execution Time: 108.9401211 seconds
Number of Results: 118
Error, Error executing substep 'Run'.
Error 56 occurred at IPSES_Modbus_x86.lvlibp:RTU Data Unit.lvclass:Read ADU Packet.vi:5030001

UUT Result: Possible reason(s):

LabVIEW: (Hex 0x38) The network operation exceeded the user-specified or system time limit.
LabVIEW: (Hex 0x38) The network operation exceeded the user-specified or system time limit.
[Error Code: 56, User-defined error code.]

Product: MOD LV
Product type: MOD LV
Comm type: COMM1_RS485
Product FW Version: 56010804
Comm FW Version: 56010000

Begin Sequence: MainSequence
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\FMEA.seq)

Initial state closed	
Status:	Passed
Module Time:	13.5898757

Begin Sequence: Initial State closed
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\FMEA.seq)

Open - Closed - Active - ON - LOG	
Status:	Done
Switch 1:	False
Swtich 2:	True
Comm Close LOG	
Status:	Done
Closed - Open - Active - ON - LOG	
Status:	Done
Switch 1:	True
Swtich 2:	False
Closed - Open - Active - ON - LOG	
Status:	Done
Switch 1:	True
Swtich 2:	False
Read Outputs LOG	
Status:	Done
Output_1_SIG:	True
Output_2_AUX:	False

Additional Results

Status:	Done
Configuration:	How is the status of LED?
Fix_Green:	FIX GREEN
Additional Results	
Status:	Done
Configuration:	How is the status of MDP?
Status:	UNLOCKED

Additional Results	
Status:	Done
Configuration:	Additional notes
Status:	"

End Sequence: Initial State closed

Close command and Switch1 closed - Switch2 open - before command	
Status:	Passed
Module Time:	24.4525579

Begin Sequence: Close command and Switch1 closed - Switch2 open - before command
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\FMEA.seq)

Closed - Open - Active - ON - LOG	
Status:	Done
Switch 1:	True
Switch 2:	False
Comm Close LOG	
Status:	Done
Closed - Open - Active - ON - LOG	
Status:	Done
Switch 1:	True
Switch 2:	False
Closed - Open - Active - ON - LOG	
Status:	Done
Switch 1:	True
Switch 2:	False
Read Outputs LOG	
Status:	Done
Output_1_SIG:	True
Output_2_AUX:	False

Additional Results	
Status:	Done
Configuration:	How is the status of LED?
Fix_Green:	FIX GREEN
Additional Results	
Status:	Done
Configuration:	How is the status of MDP?
Status:	UNLOCKED

Additional Results	
Status:	Done

Configuration:	Additional notes
Status:	"

End Sequence: Close command and Switch1 closed - Switch2 open - before command

Open command and Switch1 open - Switch2 closed - before command	
Status:	Passed
Module Time:	14.9313839

Begin Sequence: Open command and Switch1 open - Switch2 closed - before command
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\FMEA.seq)

Open - Closed - Active - ON - LOG	
Status:	Done
Switch 1:	False
Swtich 2:	True
Comm Open LOG	
Status:	Done
Open - Closed - Active - ON - LOG	
Status:	Done
Switch 1:	False
Swtich 2:	True
Closed - Open - Active - ON - LOG	
Status:	Done
Switch 1:	True
Swtich 2:	False
Read Outputs LOG	
Status:	Done
Output_1_SIG:	True
Output_2_AUX:	False

Additional Results	
Status:	Done
Configuration:	How is the status of LED?
Fix_Green:	FIX GREEN
Additional Results	
Status:	Done
Configuration:	How is the status of MDP?
Status:	UNLOCKED

Additional Results	
Status:	Done
Configuration:	Additional notes
Status:	"

End Sequence: Open command and Switch1 open - Switch2 closed - before command

Close command and switches open - during command	
Status:	Failed
Module Time:	10.2488923

Begin Sequence: Close command and switches open - during command
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\FMEA.seq)

Open - Closed - Active - ON - LOG	
Status:	Done
Switch 1:	False
Swtich 2:	True
Comm Close LOG	
Status:	Done
Open - Open - Active - ON - LOG	
Status:	Done
Switch 1:	False
Swtich 2:	False
Check Outputs	
Status:	Failed
Configuration:	Close command and failure switch 1
Output_1_SIG:	True
Output_2_AUX:	False

Additional Results	
Status:	Done
Configuration:	How is the status of LED?
Fix_Green:	FIX GREEN
Additional Results	
Status:	Done
Configuration:	How is the status of MDP?
Status:	LOCKED

Additional Results	
Status:	Done
Configuration:	Additional notes
Status:	"

End Sequence: Close command and switches open - during command

Initial state open	
Status:	Error
Error Message: Error executing substep 'Run'. Error 56 occurred at IPSES_Modbus_x86.lvlibp:RTU Data Unit.lvclass:Read ADU Packet.vi:5030001	
Possible reason(s): LabVIEW: (Hex 0x38) The network operation exceeded the user-specified or system time limit. LabVIEW: (Hex 0x38) The network operation exceeded the user-specified or system time limit. [Error Code: 56]	
Module Time:	38.758262

Begin Sequence: Initial State open
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\FMEA.seq)

Closed - Open - Active - ON - LOG	
Status:	Done
Switch 1:	True
Swtich 2:	False
Comm Open LOG	

Status:	Error
Error Message: Error executing substep 'Run'. Error 56 occurred at IPSES_Modbus_x86.lvlibp:RTU Data Unit.lvclass:Read ADU Packet.vi:5030001	
Possible reason(s): LabVIEW: (Hex 0x38) The network operation exceeded the user-specified or system time limit. LabVIEW: (Hex 0x38) The network operation exceeded the user-specified or system time limit. [Error Code: 56]	
Module Time:	0

End Sequence: Initial State open

End Sequence: MainSequence

End UUT Report

