

UUT Report

Station ID:

Serial Number:

Date:

Time:

Operator:

Execution Time:

Number of Results:

UUT Result:

Product:

Product type:

Comm type:

Product FW Version:

Comm FW Version:

IT-W-7303101

NONE

martedì 7 novembre 2023

10:22:08

administrator

25.4625603 seconds

38

Terminated

ARI LV

ARI LV

COMM1\_RS485

56010807

56010000

Begin Sequence: MainSequence  
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD\_Shared\TestStand\Sequences\MOD\General\_test.seq)

Double_trip_ARI_blocked	
Status:	Skipped
Simultaneous_trip_open	
Status:	Skipped
General and Architecture and LED	
Status:	Skipped
Input-Output	
Status:	Skipped
Power Outage	
Status:	Skipped
Motor Driver	
Status:	Skipped

Modbus Register check	
Status:	Terminated
Module Time:	16.9418006

Begin Sequence: Modbus Register check  
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD\_Shared\TestStand\Sequences\MOD\General\_test.seq)

Internal communication failure	
Status:	Done
Register Value:	OK
Additional Results	
Status:	Done
PopupString:	Check that the remote opening via modbus worked.
Status:	Passed
Additional Results	
Status:	Done
PopupString:	Check that the remote closing via modbus worked.

Status:	Passed
---------	--------

End Sequence: Modbus Register check

End Sequence: MainSequence

End UUT Report

