

UUT Report

Station ID:

Serial Number:

Date:

Time:

Operator:

Execution Time:

Number of Results:

UUT Result:

Product:

Product type:

Comm type:

Product FW Version:

Comm FW Version:

IT-W-7303101

NONE

lunedì 30 ottobre 2023

10:43:01

administrator

110.0437065 seconds

58

Terminated

MOD LV

MOD HV

COMM1_RS485

56010805

56010000

Begin Sequence: MainSequence
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\General_test.seq)

Simultaneous trip_open	
Status:	Skipped
General and Architecture and LED	
Status:	Skipped
Input-Output	
Status:	Terminated
Module Time:	71.1033095

Begin Sequence: I/O
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\General_test.seq)

Additional Results	
Status:	Done
PopupString:	Check that remote closing hasn't appened.
Status:	Passed
Additional Results	
Status:	Done
PopupString:	Check that remote closing hasn't appened.
Status:	Passed
Additional Results	
Status:	Done
PopupString:	Check that remote opening hasn't appened.
Status:	Passed
Additional Results	
Status:	Done
PopupString:	Check that remote opening hasn't appened.
Status:	Passed
Check Outputs	
Status:	Failed
Configuration:	MOD in Active State and MPD OPEN
Output 1:	True

Output 2:

True

End Sequence: I/O

End Sequence: MainSequence

End UUT Report

