UUT Report

Station ID:	IT-W-7303101
Serial Number:	NONE
Date:	mercoledì 1 febbraio 2023
Time:	15:18:44
Operator:	ITLAVIT1
Execution Time:	00:04:32.001
Number of Results:	120
UUT Result:	**Failed**
Failure Chain:	

Step	Sequence	Sequence File
Check Remote Open	MainSequence	ARI I-O.seq

Begin Sequence: MainSequence
(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\MOD\Input-Output\ARI I-O.seq)

Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that remote closing hasn't appened.
Status:	Passed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that remote closing hasn't appened.
Status:	Passed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that remote opening hasn't appened.
Status:	Passed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that remote opening hasn't appened.
Status:	Passed
Check Outputs	
Status:	Passed
TestResults/Data:	
Configuration:	MOD in Active State and MPD OPEN
Output 1:	True
Output 2:	True
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that the simultaneous opening and closing command does not affect the MOD configuration.
Status:	Passed
Check Remote Open	

Status:	Failed
Check Remote Open	
Status:	Failed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that remote opening worked.
Status:	Failed
Check Outputs	
Status:	Passed
TestResults/Data:	
Configuration:	MOD in Active State and MPD OPEN
Output 1:	False
Output 2:	True
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that the simultaneous opening and closing command does not affect the MOD configuration.
Status:	Passed
Check Outputs	
Status:	Passed
TestResults/Data:	
Configuration:	MOD in Active State and MPD OPEN
Output 1:	False
Output 2:	True
Check Outputs	
Status:	Passed
TestResults/Data:	
Configuration:	MOD in Active State and MPD HALF OPEN
Output 1:	True
Output 2:	True
Check Outputs	
Status:	Passed
TestResults/Data:	
Configuration:	MOD in Active State and MPD HALF OPEN
Output 1:	True
Output 2:	True
Check Remote Close	
Status:	Failed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that remote closing worked.
Status:	Failed
Check Outputs stand-by	
Status:	Passed
TestResults/Data:	
Configuration:	MOD in Lock State
Output 1:	False
Output 2:	True
Additional Results	
Status:	Done

TestResults/Data:	
PopupString:	Check that remote closing has not worked.
Status:	Passed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that after 3 auto-reclosing in less then 12 seconds the ARI is in Lock state.
Status:	Passed
Check Outputs	
Status:	Passed
TestResults/Data:	
Configuration:	MOD in Lock State
Output 1:	False
Output 2:	False
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that the simultaneous opening and closing command does not affect the MOD configuration.
Status:	Passed
Check Outputs	
Status:	Failed
TestResults/Data:	
Configuration:	MOD in Lock State
Output 1:	False
Output 2:	True
Check Outputs	
Status:	Failed
TestResults/Data:	
Configuration:	MOD in Lock State
Output 1:	False
Output 2:	True
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that remote closing has not worked.
Status:	Passed

End Sequence: MainSequence

End UUT Report