UUT Report

Station ID:	IT-W-7303101
Serial Number:	NONE
Date:	lunedì 30 ottobre 2023
Time:	10:23:54
Operator:	administrator
Execution Time:	111.8052853 seconds
Number of Results:	235
UUT Result:	**Passed**
Product:	MOD LV
Product type:	MOD HV
Comm type:	COMM1_RS485
Product FW Version:	56010805
Comm FW Version:	56010000

Begin Sequence: MainSequence
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\General_test.seq)

Simultaneous trip_open	
Status:	Skipped

General and Architecture and LED	
Status:	Skipped

Input-Output	
Status:	Passed
Module Time:	99.1462636

Begin Sequence: I/O
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\General_test.seq)

Additional Results	
Status:	Skipped

Additional Results	
Status:	Skipped

Additional Results	
Status:	Skipped

Additional Results	
Status:	Skipped

Check Outputs	
Status:	Skipped

Additional Results	
Status:	Skipped

Check Outputs	
Status:	Skipped

Check Outputs	
Status:	Skipped

Check Outputs	
Status:	Passed
Configuration:	MOD in Active State and MPD HALF OPEN
Output 1:	False
Output 2:	True

Check Outputs	
Status:	Passed
Configuration:	MOD in Active State and MPD HALF OPEN
Output 1:	False
Output 2:	True
Additional Results	
Status:	Done
PopupString:	Check that remote closing worked.
Status:	Passed

Check MOD Outputs	
Status:	Passed
Configuration:	MOD in Lock State
Output 1:	True
Output 2:	False
Check MOD Outputs	
Status:	Passed
Configuration:	MOD in Lock State
Output 1:	True
Output 2:	False
Additional Results	
Status:	Done
PopupString:	Check that remote closing worked.
Status:	Passed
Additional Results	
Status:	Done
PopupString:	Check that remote closing has not appened due to Dead time of 8 seconds after the trip.
Status:	Passed
Additional Results	
Status:	Done
PopupString:	Check that remote closing has appened after the Dead time of 8 seconds after the trip.
Status:	Passed

End Sequence: I/O

Power Outage	
Status:	Skipped
Motor Driver	
Status:	Skipped

Modbus Register check	
Status:	Skipped
Modbus settings check	
Status:	Skipped
COMM LED & Button	
Status:	Skipped
Firmware Upgrade	
Status:	Skipped

End Sequence: MainSequence

End UUT Report