

UUT Report

Station ID: IT-W-7303101  
Serial Number: NONE  
Date: venerdì 27 ottobre 2023  
Time: 10:21:39  
Operator: administrator  
Execution Time: 62.8934896 seconds  
Number of Results: 19  
UUT Result: Terminated  
Product: MOD LV  
Product type: MOD HV  
Comm type: COMM1\_RS485  
Product FW Version: 56010805  
Comm FW Version: 56010000

Begin Sequence: MainSequence  
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD\_Shared\TestStand\Sequences\MOD\General\_test.seq)

Simultaneous trip_open	
Status:	Skipped
General and Architecture and LED	
Status:	Terminated
Module Time:	55.953532

Begin Sequence: General and Architecture and LED  
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD\_Shared\TestStand\Sequences\MOD\General\_test.seq)

Additional Results	
Status:	Done
PopupString:	Check that manual opening and closing of the device shall be possible when the device is power off and the LED is OFF.
Status:	Passed
Additional Results	
Status:	Done
PopupString:	Check that manual opening and closing of the device shall be possible when the device is power ON and in NOT-Active state.
Status:	Passed
Check LED Status	
Status:	Failed
Additional Results	
Status:	Done
PopupString:	Check that the LED is "Blinking Green" in both active and close configurations.
Status:	Failed

End Sequence: General and Architecture and LED

End Sequence: MainSequence

End UUT Report

