UUT Report

Station ID:	IT-W-7303101
Serial Number:	NONE
Date:	lunedì 6 novembre 2023
Time:	11:04:40
Operator:	administrator
Execution Time:	79.005999 seconds
Number of Results:	204
UUT Result:	**Terminated**
Product:	MOD LV
Product type:	MOD LV
Comm type:	COMM1_RS485
Product FW Version:	56010807
Comm FW Version:	56010000

Begin Sequence: MainSequence
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\General_test.seq)

Simultaneous trip_open	
Status:	Skipped

General and Architecture and LED	
Status:	Skipped

Input-Output	
Status:	Terminated
Module Time:	76.1899814

Begin Sequence: I/O
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\General_test.seq)

Additional Results	
Status:	Skipped

Additional Results	
Status:	Skipped

Additional Results	
Status:	Skipped

Additional Results	
Status:	Skipped

Check Outputs	
Status:	Skipped

Additional Results	
Status:	Skipped

Check Outputs	
Status:	Skipped

Check Outputs	
Status:	Skipped

Check Outputs	
Status:	Skipped

Check Outputs	
Status:	Skipped

Additional Results	
Status:	Skipped

Check MOD Outputs	
Status:	Failed
Configuration:	MOD in Lock State
Output 1:	False
Output 2:	True

Check MOD Outputs	
Status:	Passed
Configuration:	MOD in Lock State
Output 1:	True
Output 2:	False

Additional Results	
Status:	Done
PopupString:	Check that remote closing worked.
Status:	Passed

End Sequence: I/O

End Sequence: MainSequence

End UUT Report