

UUT Report

Station ID: IT-W-7303101
Serial Number: NONE
Date: martedì 21 febbraio 2023
Time: 10:47:52
Operator: ITLAVIT1
Execution Time: 00:05:13.057
Number of Results: 167
UUT Result: Passed

Begin Sequence: MainSequence
(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\MOD\Motor Driver\MOD Motor Driver.seq)

MPD MODEL	
Status:	Done
TestResults/Data:	
MPD MODEL:	F202
Power Consumption at rest	
Status:	Passed
Numeric:	0.5184
Limits:	
Low:	1
Comparison Type:	LE(<=)
TestResults/Data:	
Configuration:	At Rest
Power Consumption during opening	
Status:	Passed
Numeric:	12
Limits:	
Low:	25
Comparison Type:	LE(<=)
TestResults/Data:	
Configuration:	Opening
Power Consumption during closing	
Status:	Passed
Numeric:	12.72
Limits:	
Low:	25
Comparison Type:	LE(<=)
TestResults/Data:	
Configuration:	Closing
Power Consumption at rest after	
Status:	Passed
Numeric:	0.456
Limits:	
Low:	1

Comparison Type:	LE(<=)
TestResults/Data:	
Configuration:	At Rest

End Sequence: MainSequence

End UUT Report

