

UUT Report

Station ID: IT-W-7303101  
Serial Number: NONE  
Date: lunedì 6 novembre 2023  
Time: 14:37:18  
Operator: administrator  
Execution Time: 463.2628507 seconds  
Number of Results: 295  
UUT Result: Failed  
Product: ARI LV  
Product type: NO COMM  
Comm type: NO COMM  
Product FW Version: NO COMM  
Comm FW Version: NO COMM  
Failure Chain:

Step	Sequence	Sequence File
<a href="#">Check Outputs stand-by</a>	I/O	General_test.seq
<a href="#">Input-Output</a>	MainSequence	General_test.seq



Begin Sequence: MainSequence  
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD\_Shared\TestStand\Sequences\MOD\General\_test.seq)

Simultaneous trip_open	
Status:	Skipped
General and Architecture and LED	
Status:	Skipped
Input-Output	
Status:	Failed
Module Time:	436.7667169

Begin Sequence: I/O  
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD\_Shared\TestStand\Sequences\MOD\General\_test.seq)

Additional Results	
Status:	Done
PopupString:	Check that remote closing hasn't appened.
Status:	Passed
Additional Results	
Status:	Done
PopupString:	Check that remote closing hasn't appened.
Status:	Passed
Additional Results	
Status:	Done
PopupString:	Check that remote opening hasn't appened.
Status:	Passed
Additional Results	
Status:	Done
PopupString:	Check that remote opening hasn't appened.
Status:	Passed
Check Outputs	

Status:	Passed
Configuration:	MOD in Active State and MPD OPEN
Output 1:	False
Output 2:	True
Additional Results	
Status:	Done
PopupString:	Check that remote opening worked.
Status:	Passed
Check Outputs	
Status:	Passed
Configuration:	MOD in Active State and MPD OPEN
Output 1:	False
Output 2:	False
Check Outputs	
Status:	Passed
Configuration:	MOD in Active State and MPD OPEN
Output 1:	False
Output 2:	False
Check Outputs	
Status:	Passed
Configuration:	MOD in Active State and MPD HALF OPEN
Output 1:	False
Output 2:	True
Check Outputs	
Status:	Passed
Configuration:	MOD in Active State and MPD HALF OPEN
Output 1:	False
Output 2:	True
Additional Results	
Status:	Done
PopupString:	Check that remote closing worked.
Status:	Passed

Check Outputs stand-by	
Status:	Failed
Configuration:	MOD in Lock State
Output 1:	True
Output 2:	False
Additional Results	
Status:	Done
PopupString:	Check that closing has not worked due to input command but for the auto-closing.
Status:	Passed
Check Outputs stand-by	
Status:	Failed
Configuration:	MOD in Lock State
Output 1:	False
Output 2:	True
Check Outputs stand-by	
Status:	Failed
Configuration:	MOD in Lock State
Output 1:	False
Output 2:	False

Additional Results	
Status:	Done
PopupString:	Check that closing has not worked due to input command but for the auto-reclosing.
Status:	Passed
Check Lock state	
Status:	Failed
Additional Results	
Status:	Done
PopupString:	Check ARI is in Lock state.
Status:	Failed
Check Outputs	
Status:	Failed
Configuration:	MOD in Lock State
Output 1:	True
Output 2:	True
Check Outputs	
Status:	Failed
Configuration:	MOD in Lock State
Output 1:	True
Output 2:	False
Additional Results	
Status:	Done
PopupString:	Check that remote closing not worked.
Status:	Passed

End Sequence: I/O

Power Outage	
Status:	Skipped
Motor Driver	
Status:	Skipped

End Sequence: MainSequence

End UUT Report

---