

UUT Report

Station ID: IT-W-7303101
Serial Number: M086AB1000
Date: venerdì 20 gennaio 2023
Time: 13:58:48
Operator: ITLAVIT1
Execution Time: 00:01:37.432
Number of Results: 38
UUT Result: Passed

Begin Sequence: MainSequence
(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\M4M\PMD-4562.seq)

DUT recap	
Status:	Done
TestResults/Data:	
Serial Number:	M086AB1000
Type Designator:	M4M21SEA
FW Version:	P2.6.14.0

Pulse Output 1 and 2	
Status:	Passed
Module Time:	95.4295

Begin Sequence: Pulse Output 1 and 2
(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\M4M\PMD-4562.seq)

Pass/Fail Test	
Status:	Passed
Pass/Fail Test	
Status:	Passed
Pass/Fail Test	
Status:	Passed
Active energy pulses check	
Status:	Passed
Numeric:	163
Limits:	
Low:	161
High:	171
Comparison Type:	GELE(>= <=)
Active energy pulses check	
Status:	Passed
Numeric:	45
Limits:	
Low:	43

High:	53
Comparison Type:	GELE(>= <=)

End Sequence: Pulse Output 1 and 2

End Sequence: MainSequence

End UUT Report
