

UUT Report

Station ID: IT-W-7303101
Serial Number: NONE
Date: martedì 10 ottobre 2023
Time: 16:16:55
Operator: administrator
Execution Time: 151.6981438 seconds
Number of Results: 138
UUT Result: Passed
Product: ARI LV
Product type: ARI LV
Comm type: COMM1_RS485
Product FW Version: 56010804
Comm FW Version: 56010000

Begin Sequence: MainSequence
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\General_test.seq)

General and Architecture and LED	
Status:	Skipped
Input-Output	
Status:	Skipped
Power Outage	
Status:	Passed
Module Time:	135.5731306

Begin Sequence: Power Outage
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\General_test.seq)

Additional Results	
Status:	Done
PopupString:	Check that the MOD open automatically the MPD at power On without reclosing.
Status:	Passed
Additional Results	
Status:	Skipped
Additional Results	
Status:	Done
PopupString:	Check that the MOD closes automatically the MPD at power On after power fail.
Status:	Passed
Additional Results	
Status:	Done
PopupString:	Check that the MOD open automatically the MPD at power On and reclose without dead time.
Status:	Passed

End Sequence: Power Outage

Motor Driver	
Status:	Skipped

Modbus Register check	
Status:	Skipped
Modbus settings check	
Status:	Skipped
COMM LED & Button	
Status:	Skipped
Firmware Upgrade	
Status:	Skipped

End Sequence: MainSequence

End UUT Report

