

UUT Report

Station ID: IT-W-7303101  
Serial Number: NONE  
Date: lunedì 30 ottobre 2023  
Time: 15:15:26  
Operator: administrator  
Execution Time: 115.6038035 seconds  
Number of Results: 124  
UUT Result: Terminated  
Product: MOD LV  
Product type: MOD LV  
Comm type: COMM1\_RS485  
Product FW Version: 56010804  
Comm FW Version: 56010000

Begin Sequence: MainSequence  
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD\_Shared\TestStand\Sequences\MOD\FMEA.seq)

Initial state closed	
Status:	Passed
Module Time:	28.8398565

Begin Sequence: Initial State closed  
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD\_Shared\TestStand\Sequences\MOD\FMEA.seq)

Open - Closed - Active - ON - LOG	
Status:	Done
Switch 1:	False
Switch 2:	True
Comm Close LOG	
Status:	Done
Closed - Open - Active - ON - LOG	
Status:	Done
Switch 1:	True
Switch 2:	False
Closed - Open - Active - ON - LOG	
Status:	Done
Switch 1:	True
Switch 2:	False
Read Outputs LOG	
Status:	Done
Output_1_SIG:	True
Output_2_AUX:	False

Additional Results	
Status:	Done
Configuration:	How is the status of LED?
Fix_Green:	FIX GREEN
Additional Results	
Status:	Done
Configuration:	How is the status of MDP?
Status:	UNLOCKED

Additional Results	
Status:	Done
Configuration:	Additional notes
Status:	"

**End Sequence: Initial State closed**

Close command and Switch1 closed - Switch2 open - before command	
Status:	Passed
Module Time:	29.1390567

**Begin Sequence: Close command and Switch1 closed - Switch2 open - before command**  
**(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD\_Shared\TestStand\Sequences\MOD\FMEA.seq)**

Closed - Open - Active - ON - LOG	
Status:	Done
Switch 1:	True
Swich 2:	False
Comm Close LOG	
Status:	Done
Closed - Open - Active - ON - LOG	
Status:	Done
Switch 1:	True
Swich 2:	False
Closed - Open - Active - ON - LOG	
Status:	Done
Switch 1:	True
Swich 2:	False
Read Outputs LOG	
Status:	Done
Output_1_SIG:	True
Output_2_AUX:	False

Additional Results	
Status:	Done
Configuration:	How is the status of LED?
Fix_Green:	FIX GREEN
Additional Results	
Status:	Done
Configuration:	How is the status of MDP?
Status:	UNLOCKED

Additional Results	
Status:	Done
Configuration:	Additional notes
Status:	"

**End Sequence: Close command and Switch1 closed - Switch2 open - before command**

Open command and Switch1 open - Switch2 closed - before command	
Status:	Passed
Module Time:	15.158322

**Begin Sequence: Open command and Switch1 open - Switch2 closed - before command**  
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD\_Shared\TestStand\Sequences\MOD\FMEA.seq)

Open - Closed - Active - ON - LOG	
Status:	Done
Switch 1:	False
Switch 2:	True
Comm Open LOG	
Status:	Done
Open - Closed - Active - ON - LOG	
Status:	Done
Switch 1:	False
Switch 2:	True
Closed - Open - Active - ON - LOG	
Status:	Done
Switch 1:	True
Switch 2:	False
Read Outputs LOG	
Status:	Done
Output_1_SIG:	True
Output_2_AUX:	False

Additional Results	
Status:	Done
Configuration:	How is the status of LED?
Fix_Green:	FIX GREEN
Additional Results	
Status:	Done
Configuration:	How is the status of MDP?
Status:	UNLOCKED

Additional Results	
Status:	Done
Configuration:	Additional notes
Status:	"

**End Sequence: Open command and Switch1 open - Switch2 closed - before command**

Close command and switches open - during command	
Status:	Failed
Module Time:	17.546933

**Begin Sequence: Close command and switches open - during command**  
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD\_Shared\TestStand\Sequences\MOD\FMEA.seq)

Open - Closed - Active - ON - LOG	
Status:	Done
Switch 1:	False
Switch 2:	True
Comm Close LOG	
Status:	Done

Open - Open - Active - ON - LOG	
Status:	Done
Switch 1:	False
Switch 2:	False
Check Outputs	
Status:	Failed
Configuration:	Close command and failure switch 1
Output_1_SIG:	True
Output_2_AUX:	False

Additional Results	
Status:	Done
Configuration:	How is the status of LED?
Fix_Green:	FIX GREEN
Additional Results	
Status:	Done
Configuration:	How is the status of MDP?
Status:	LOCKED

Additional Results	
Status:	Done
Configuration:	Additional notes
Status:	"

End Sequence: Close command and switches open - during command

Initial state open	
Status:	Terminated
Module Time:	19.1227557

Begin Sequence: Initial State open  
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD\_Shared\TestStand\Sequences\MOD\FMEA.seq)

Closed - Open - Active - ON - LOG	
Status:	Done
Switch 1:	True
Switch 2:	False
Comm Open LOG	
Status:	Done
Open - Closed - Active - ON - LOG	
Status:	Done
Switch 1:	False
Switch 2:	True
Closed - Open - Active - ON - LOG	
Status:	Done
Switch 1:	True
Switch 2:	False

End Sequence: Initial State open

End Sequence: MainSequence

End UUT Report

---