

UUT Report

Station ID: IT-W-7303101
Serial Number: NONE
Date: lunedì 23 ottobre 2023
Time: 10:04:50
Operator: administrator
Execution Time: 38.2689679 seconds
Number of Results: 12
UUT Result: Terminated
Product: MOD HV
Product type: MOD HV
Comm type: COMM1_RS485
Product FW Version: 56010804
Comm FW Version: 56010000

Begin Sequence: MainSequence
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\General_test.seq)

| | |
|----------------------------------|------------|
| Simultaneous trip_open | |
| Status: | Skipped |
| General and Architecture and LED | |
| Status: | Terminated |
| Module Time: | 36.7921989 |

Begin Sequence: General and Architecture and LED
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\General_test.seq)

| | |
|-------------------------|--|
| Check Manual Open/Close | |
| Status: | Failed |
| Additional Results | |
| Status: | Done |
| PopupString: | Check that manual opening and closing of the device shall be possible when the device is power off and the LED is OFF. |
| Status: | Failed |

End Sequence: General and Architecture and LED

End Sequence: MainSequence

End UUT Report