

UUT Report

Station ID: IT-W-7303101
Serial Number: M086AB1000
Date: mercoledì 11 gennaio 2023
Time: 09:46:52
Operator: ITLAVIT1
Execution Time: 00:05:07.001
Number of Results: 38
UUT Result: Failed
Failure Chain:

Step	Sequence	Sequence File
Check slot 2 conf via HMI	Pulse Output 1 and 2	PMD-4562.seq
Pulse Output 1 and 2	MainSequence	PMD-4562.seq

Begin Sequence: MainSequence
(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\M4M\PMD-4562.seq)

DUT recap	
Status:	Done
TestResults/Data:	
Serial Number:	M086AB1000
Type Designator:	M4M20SEA
FW Version:	P2.6.14.0

Pulse Output 1 and 2	
Status:	Failed
Module Time:	172.304

Begin Sequence: Pulse Output 1 and 2
(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\M4M\PMD-4562.seq)

Check slot 2 conf via HMI	
Status:	Failed

Active energy pulses check	
Status:	Failed
Numeric:	0
Limits:	
Low:	161
High:	171
Comparison Type:	GELE(>= <=)
Active energy pulses check	
Status:	Failed

Numeric:	1
Limits:	
Low:	43
High:	53
Comparison Type:	GELE(>= <=)

End Sequence: Pulse Output 1 and 2

End Sequence: MainSequence

End UUT Report

