

# UUT Report

Station ID:

Serial Number:

Date:

Time:

Operator:

Execution Time:

Number of Results:

UUT Result:

IT-W-7303101

NONE

mercoledì 1 febbraio 2023

16:37:59

ITLAVIT1

00:01:39.973

105

Terminated

Begin Sequence: MainSequence  
(C:\Users\itlavit1\OneDrive - ABB\LabRnD\_Shared\TestStand\Sequences\MOD\RS485  
Modbus Communication\ARI Registers check.seq)

Internal communication failure	
Status:	Skipped
Additional Results	
Status:	Skipped
Additional Results	
Status:	Skipped
Additional Results	
Status:	Skipped
Additional Results	
Status:	Skipped
input	
Status:	Done
TestResults/Data:	
Register Value:	Disable
Pass/Fail Test	
Status:	Passed
Communication	
Status:	Done
TestResults/Data:	
Register Value:	Disable
Pass/Fail Test	
Status:	Passed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that the remote closing via input has not worked.
Status:	Passed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that the remote closing via modbus has not worked.
Status:	Passed

Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that the remote closing via input has not worked.
Status:	Passed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that the remote closing via modbus has not worked.
Status:	Passed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that the remote opening via input has not worked.
Status:	Passed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that the remote opening via modbus has not worked.
Status:	Passed
Popup PassFail	
Status:	Failed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that the remote opening via input has not worked.
Status:	Failed
Popup PassFail	
Status:	Failed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that the remote opening via modbus has not worked.
Status:	Failed
input	
Status:	Done
TestResults/Data:	
Register Value:	Enable
Pass/Fail Test	
Status:	Passed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that the remote closing via modbus has not worked.
Status:	Passed
Popup PassFail	
Status:	Failed
Additional Results	

Status:	Done
TestResults/Data:	
PopupString:	Check that the remote closing via input worked.
Status:	Failed
Popup PassFail	
Status:	Failed

End Sequence: MainSequence

End UUT Report

