

UUT Report

Station ID: IT-W-7303101  
Serial Number: NONE  
Date: giovedì 6 aprile 2023  
Time: 12:42:01  
Operator: ITLAVIT1  
Execution Time: 00:01:08.183  
Number of Results: 351  
UUT Result: Passed  
Serial Number: "  
Type Designator: "  
FW Version: 0.14.0  
Power Supply: Omicron

Begin Sequence: MainSequence  
(C:\Users\itlavit1\OneDrive - ABB\LabRnD\_Shared\TestStand\Sequences\EQ  
Meter\Modbus RTU Settings.seq)

DUT info	
Status:	Done
TestResults/Data:	
Serial Number:	"
Type Designator:	"
FW Version:	0.14.0

Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Address:	1
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	9600
Parity:	Even
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	9600
Parity:	None
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	9600
Parity:	Odd
Pass/Fail Test	
Status:	Passed
TestResults/Data:	

Baud Rate:	19200
Parity:	Even
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	19200
Parity:	None
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	19200
Parity:	Odd
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	38400
Parity:	Even
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	38400
Parity:	None
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	38400
Parity:	Odd
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	57600
Parity:	Even
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	57600
Parity:	None
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	57600
Parity:	Odd
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	115200
Parity:	Even
Pass/Fail Test	
Status:	Passed

TestResults/Data:	
Baud Rate:	115200
Parity:	None
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	115200
Parity:	Odd

**End Sequence: MainSequence**

**End UUT Report**

