

UUT Report

Station ID: IT-W-7303101
Serial Number: NONE
Date: giovedì 12 ottobre 2023
Time: 11:43:01
Operator: administrator
Execution Time: 454.0536866 seconds
Number of Results: 8
UUT Result: Terminated
Product: MOD LV
Product type: MOD LV
Comm type: COMM1_RS485
Product FW Version: 56010709
Comm FW Version: 56010000

Begin Sequence: MainSequence
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\General_test.seq)

General and Architecture and LED	
Status:	Terminated
Module Time:	449.4306817

Begin Sequence: General and Architecture and LED
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\General_test.seq)

Additional Results	
Status:	Done
PopupString:	Check that manual opening and closing of the device shall be possible when the device is power off and the LED is OFF.
Status:	Passed

End Sequence: General and Architecture and LED

End Sequence: MainSequence

End UUT Report