UUT Report

Station ID:	IT-W-7303101
Serial Number:	NONE
Date:	**lunedì 9 ottobre 2023**
Time:	10:32:04
Operator:	administrator
Execution Time:	183.7362515 seconds
Number of Results:	71
UUT Result:	**Terminated**
Product:	ARI LV
Product type:	ARI HV
Comm type:	COMM1_RS485
Product FW Version:	56010802
Comm FW Version:	56010000

Begin Sequence: MainSequence
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\Blocked MOD.seq)

Check Lock	
Status:	Failed

Additional Results	
Status:	Done
PopupString:	Check that ARI reach Lock state after 3 trip due to the NO-reset of reclosing attempts during the power fail before the autorecolsing.
Status:	Failed

Check Lock	
Status:	Failed

Additional Results	
Status:	Done
PopupString:	Check that ARI reach Lock state after 4 trip due to the reset of reclosing attempts during the power fail.
Status:	Failed

End Sequence: MainSequence

End UUT Report