UUT Report

Station ID:	**IT-W-7303101**
Serial Number:	**NONE**
Date:	**mercoledì 22 marzo 2023**
Time:	**11:06:13**
Operator:	**ITLAVIT1**
Execution Time:	**00:01:32.573**
Number of Results:	**77**
UUT Result:	**Terminated**

Begin Sequence: MainSequence
(C:\Users\itlavit1\OneDrive –
ABB\LabRnD_Shared\TestStand\Sequences\MOD\Complete_test_modified_Germany.seq)

UUT Parameters	
Status:	Done
TestResults/Data:	
Product Name:	MOD LV
Communication Module:	NONE
UUT_info_comm	
Status:	Done
TestResults/Data:	
Product type:	"
COMM type:	"
Product Firmware version:	"
COMM Firmware version:	"
General and Architecture and LED	
Status:	Skipped
Input-Output	
Status:	Terminated
Module Time:	88.8217

Begin Sequence: I/O
(C:\Users\itlavit1\OneDrive –
ABB\LabRnD_Shared\TestStand\Sequences\MOD\Complete_test_modified_Germany.seq)

Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that remote closing hasn't appened.
Status:	Passed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that remote closing hasn't appened.
Status:	Passed
Additional Results	

Status:	Done
TestResults/Data:	
PopupString:	Check that remote opening hasn't appened.
Status:	Passed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that remote opening hasn't appened.
Status:	Passed
Check Outputs	
Status:	Passed
TestResults/Data:	
Configuration:	MOD in Active State and MPD OPEN
Output 1:	False
Output 2:	True
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that remote opening worked.
Status:	Passed
Check Outputs	
Status:	Passed
TestResults/Data:	
Configuration:	MOD in Active State and MPD OPEN
Output 1:	True
Output 2:	True
Check Outputs	
Status:	Passed
TestResults/Data:	
Configuration:	MOD in Active State and MPD OPEN
Output 1:	True
Output 2:	True
Check Outputs	
Status:	Passed
TestResults/Data:	
Configuration:	MOD in Active State and MPD HALF OPEN
Output 1:	False
Output 2:	True
Check Outputs	
Status:	Passed
TestResults/Data:	
Configuration:	MOD in Active State and MPD HALF OPEN
Output 1:	False
Output 2:	True
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that remote closing worked.
Status:	Passed

Check MOD Outputs	
Status:	Failed
TestResults/Data:	
Configuration:	MOD in Lock State
Output 1:	True
Output 2:	False

End Sequence: I/O

End Sequence: MainSequence

End UUT Report