


Station ID:	IT-W-7303101
Serial Number:	NONE
Date:	venerdì 9 giugno 2023
Time:	14:59:07
Operator:	administrator
Execution Time:	387.8335143 seconds
Number of Results:	341
UUT Result:	Passed
Serial Number:	4294967295
Type Designator:	B1-D3NB-111A
FW Version:	0.16.1
Power Supply:	Omicron

DUT info	
Status:	Done
Serial Number:	4294967295
Type Designator:	B1-D3NB-111A
FW Version:	0.16.1

Test Result	
Status:	Done
Repeatability cycle result:	Failed
Current:	0.25
Power Factor:	1
Graph in report - LOG	
Status:	Done
Accuracy[0..3][0..19]:	
Current:	0.25
Power Factor:	1
Max difference	

Status:	Done
MAX Difference:	0.006966333353833
Minimum value:	-0.4415968282905
Maximum value:	-0.4346304949367

End Sequence: MainSequence

End UUT Report

