UUT Report

Station ID:	IT-W-7303101
Serial Number:	NONE
Date:	lunedì 6 novembre 2023
Time:	14:50:30
Operator:	administrator
Execution Time:	144.0372174 seconds
Number of Results:	279
UUT Result:	**Failed**
Product:	ARI LV
Product type:	NO COMM
Comm type:	NO COMM
Product FW Version:	NO COMM
Comm FW Version:	NO COMM
Failure Chain:	

Step	Sequence	Sequence File
Check Outputs	I/O	General_test.seq
Input-Output	MainSequence	General_test.seq

Begin Sequence: MainSequence
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\General_test.seq)

Simultaneous trip_open	
Status:	Skipped

General and Architecture and LED	
Status:	Skipped

Input-Output	
Status:	Failed
Module Time:	118.2766778

Begin Sequence: I/O
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\General_test.seq)

Additional Results	
Status:	Skipped

Additional Results	
Status:	Skipped

Additional Results	
Status:	Skipped

Additional Results	
Status:	Skipped

Check Outputs	
Status:	Skipped

Additional Results	
Status:	Skipped

Check Outputs	
Status:	Skipped

Check Outputs	
Status:	Skipped

Check Outputs	
Status:	Skipped

Check Outputs	
Status:	Skipped

Additional Results	
Status:	Skipped

Check Outputs stand-by	
Status:	Passed
Configuration:	MOD in Lock State
Output 1:	False
Output 2:	True

Additional Results	
Status:	Done
PopupString:	Check that closing has not worked due to input command but for the auto-reclosing.
Status:	Passed

Additional Results	
Status:	Done
PopupString:	Check ARI is in Lock state.
Status:	Passed

Check Outputs	
Status:	Passed
Configuration:	MOD in Lock State
Output 1:	True
Output 2:	False

Check Outputs	
Status:	Failed
Configuration:	MOD in Lock State
Output 1:	True
Output 2:	False

Additional Results	
Status:	Done
PopupString:	Check that remote closing not worked.
Status:	Passed

End Sequence: I/O

Power Outage	
Status:	Skipped

Motor Driver	
Status:	Skipped

End Sequence: MainSequence

End UUT Report