

UUT Report

Station ID: IT-W-7303101  
Serial Number: NONE  
Date: mercoledì 18 ottobre 2023  
Time: 16:26:01  
Operator: administrator  
Execution Time: 224.4008578 seconds  
Number of Results: 218  
UUT Result: Terminated  
Product: MOD LV  
Product type: MOD LV  
Comm type: COMM1\_RS485  
Product FW Version: 56010804  
Comm FW Version: 56010000

Begin Sequence: MainSequence  
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD\_Shared\TestStand\Sequences\MOD\FMEA.seq)

Initial state closed	
Status:	Passed
Module Time:	25.0373907

Begin Sequence: Initial State closed  
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD\_Shared\TestStand\Sequences\MOD\FMEA.seq)

Open - Closed - Active - ON - LOG	
Status:	Done
Switch 1:	False
Switch 2:	True
Comm Close LOG	
Status:	Done
Closed - Open - Active - ON - LOG	
Status:	Done
Switch 1:	True
Switch 2:	False
Closed - Open - Active - ON - LOG	
Status:	Done
Switch 1:	True
Switch 2:	False
Read Outputs LOG	
Status:	Done
Output_1_SIG:	True
Output_2_AUX:	False

Additional Results	
Status:	Done
Configuration:	How is the status of LED?
Fix_Green:	FIX GREEN
Additional Results	
Status:	Done
Configuration:	How is the status of MDP?
Status:	UNLOCKED

Additional Results	
Status:	Done
Configuration:	Additional notes
Status:	"

**End Sequence: Initial State closed**

Close command and Switch1 closed - Switch2 open - before command	
Status:	Passed
Module Time:	23.1093353

**Begin Sequence: Close command and Switch1 closed - Switch2 open - before command**  
**(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD\_Shared\TestStand\Sequences\MOD\FMEA.seq)**

Closed - Open - Active - ON - LOG	
Status:	Done
Switch 1:	True
Swich 2:	False
Comm Close LOG	
Status:	Done
Closed - Open - Active - ON - LOG	
Status:	Done
Switch 1:	True
Swich 2:	False
Closed - Open - Active - ON - LOG	
Status:	Done
Switch 1:	True
Swich 2:	False
Read Outputs LOG	
Status:	Done
Output_1_SIG:	True
Output_2_AUX:	False

Additional Results	
Status:	Done
Configuration:	How is the status of LED?
Fix_Green:	FIX GREEN
Additional Results	
Status:	Done
Configuration:	How is the status of MDP?
Status:	UNLOCKED

Additional Results	
Status:	Done
Configuration:	Additional notes
Status:	"

**End Sequence: Close command and Switch1 closed - Switch2 open - before command**

Open command and Switch1 open - Switch2 closed - before command	
Status:	Passed
Module Time:	15.3352634

**Begin Sequence: Open command and Switch1 open - Switch2 closed - before command**  
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD\_Shared\TestStand\Sequences\MOD\FMEA.seq)

Open - Closed - Active - ON - LOG	
Status:	Done
Switch 1:	False
Switch 2:	True
Comm Open LOG	
Status:	Done
Open - Closed - Active - ON - LOG	
Status:	Done
Switch 1:	False
Switch 2:	True
Closed - Open - Active - ON - LOG	
Status:	Done
Switch 1:	True
Switch 2:	False
Read Outputs LOG	
Status:	Done
Output_1_SIG:	True
Output_2_AUX:	False

Additional Results	
Status:	Done
Configuration:	How is the status of LED?
Fix_Green:	FIX GREEN
Additional Results	
Status:	Done
Configuration:	How is the status of MDP?
Status:	UNLOCKED

Additional Results	
Status:	Done
Configuration:	Additional notes
Status:	"

**End Sequence: Open command and Switch1 open - Switch2 closed - before command**

Close command and switches open - during command	
Status:	Failed
Module Time:	28.682134

**Begin Sequence: Close command and switches open - during command**  
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD\_Shared\TestStand\Sequences\MOD\FMEA.seq)

Open - Closed - Active - ON - LOG	
Status:	Done
Switch 1:	False
Switch 2:	True
Comm Close LOG	
Status:	Done

Open - Open - Active - ON - LOG	
Status:	Done
Switch 1:	False
Switch 2:	False
Check Outputs	
Status:	Failed
Configuration:	Close command and failure switch 1
Output_1_SIG:	True
Output_2_AUX:	False

Additional Results	
Status:	Done
Configuration:	How is the status of LED?
Fix_Green:	FIX GREEN
Additional Results	
Status:	Done
Configuration:	How is the status of MDP?
Status:	LOCKED

Additional Results	
Status:	Done
Configuration:	Additional notes
Status:	Closing manœuvre done

End Sequence: Close command and switches open - during command

Initial state open	
Status:	Passed
Module Time:	17.4322649

Begin Sequence: Initial State open  
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD\_Shared\TestStand\Sequences\MOD\FMEA.seq)

Closed - Open - Active - ON - LOG	
Status:	Done
Switch 1:	True
Switch 2:	False
Comm Open LOG	
Status:	Done
Open - Closed - Active - ON - LOG	
Status:	Done
Switch 1:	False
Switch 2:	True
Closed - Open - Active - ON - LOG	
Status:	Done
Switch 1:	True
Switch 2:	False
Read Outputs LOG	
Status:	Done
Output_1_SIG:	True
Output_2_AUX:	False

Additional Results	

Status:	Done
Configuration:	How is the status of LED?
Fix_Green:	FIX GREEN
Additional Results	
Status:	Done
Configuration:	How is the status of MDP?
Status:	UNLOCKED

Additional Results	
Status:	Done
Configuration:	Additional notes
Status:	"

**End Sequence: Initial State open**

Close command and switches closed - during command	
Status:	Passed
Module Time:	19.4444351

**Begin Sequence: Close command and switches closed - during command**  
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD\_Shared\TestStand\Sequences\MOD\FMEA.seq)

Open - Closed - Active - ON - LOG	
Status:	Done
Switch 1:	False
Switch 2:	True
Comm Close LOG	
Status:	Done
Closed - Closed - Active - ON - LOG	
Status:	Done
Switch 1:	True
Switch 2:	True
Check Outputs	
Status:	Passed
Configuration:	Close command and failure switch 2
Output_1_SIG:	False
Output_2_AUX:	False

Additional Results	
Status:	Done
Configuration:	How is the status of LED?
Fix_Green:	FIX GREEN
Additional Results	
Status:	Done
Configuration:	How is the status of MDP?
Status:	LOCKED

Additional Results	
Status:	Done
Configuration:	Additional notes
Status:	Closing manœuvre done

**End Sequence: Close command and switches closed - during command**

Initial state open	
Status:	Passed
Module Time:	22.2395676

#### Begin Sequence: Initial State open

(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD\_Shared\TestStand\Sequences\MOD\FMEA.seq)

Closed - Open - Active - ON - LOG	
Status:	Done
Switch 1:	True
Switch 2:	False
Comm Open LOG	
Status:	Done
Open - Closed - Active - ON - LOG	
Status:	Done
Switch 1:	False
Switch 2:	True
Closed - Open - Active - ON - LOG	
Status:	Done
Switch 1:	True
Switch 2:	False
Read Outputs LOG	
Status:	Done
Output_1_SIG:	True
Output_2_AUX:	False

Additional Results	
Status:	Done
Configuration:	How is the status of LED?
Fix_Green:	FIX GREEN
Additional Results	
Status:	Done
Configuration:	How is the status of MDP?
Status:	UNLOCKED

Additional Results	
Status:	Done
Configuration:	Additional notes
Status:	"

#### End Sequence: Initial State open

Open command and switches closed	
Status:	Failed
Module Time:	26.0712584

#### Begin Sequence: Open command and switches closed - during command

(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD\_Shared\TestStand\Sequences\MOD\FMEA.seq)

Closed - Open - Active - ON - LOG	
Status:	Done
Switch 1:	True
Switch 2:	False

Comm Open LOG	
Status:	Done
Closed - Closed - Active - ON - LOG	
Status:	Done
Switch 1:	True
Swtich 2:	True
Check Outputs	
Status:	Failed
Configuration:	Open command and failure switch 1
Output_1_SIG:	True
Output_2_AUX:	False

Additional Results	
Status:	Done
Configuration:	How is the status of LED?
Fix_Green:	FIX GREEN
Additional Results	
Status:	Done
Configuration:	How is the status of MDP?
Status:	LOCKED

Additional Results	
Status:	Done
Configuration:	Additional notes
Status:	Opening manœuvre done

End Sequence: Open command and switches closed - during command

Open command and switches open	
Status:	Terminated
Module Time:	30.2074144

Begin Sequence: Open command and switches open - during command  
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD\_Shared\TestStand\Sequences\MOD\FMEA.seq)

Closed - Open - Active - ON - LOG	
Status:	Done
Switch 1:	True
Swtich 2:	False

End Sequence: Open command and switches open - during command

End Sequence: MainSequence

End UUT Report

---