

UUT Report

Station ID: IT-W-7303101
Serial Number: NONE
Date: martedì 20 dicembre 2022
Time: 11:40:04
Operator: ITLAVIT1
Execution Time: 51.779 seconds
Number of Results: 335
UUT Result: Passed

Begin Sequence: MainSequence
(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\Modbus RTU settings.seq)

DUT recap	
Status:	Done
TestResults/Data:	
Serial Number:	"
Type Designator:	B1D3MB111A
FW Version:	0.11.0

Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Address:	1
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	9600
Parity:	Even
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	9600
Parity:	None
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	9600
Parity:	Odd
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	19200
Parity:	Even
Pass/Fail Test	
Status:	Passed

TestResults/Data:	
Baud Rate:	19200
Parity:	None
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	19200
Parity:	Odd
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	38400
Parity:	Even
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	38400
Parity:	None
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	38400
Parity:	Odd
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	57600
Parity:	Even
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	57600
Parity:	None
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	57600
Parity:	Odd
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	115200
Parity:	Even
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	115200
Parity:	None
Pass/Fail Test	

Status:	Passed
TestResults/Data:	
Baud Rate:	115200
Parity:	Odd

End Sequence: MainSequence

End UUT Report

