

UUT Report

Station ID:

Serial Number:

Date:

Time:

Operator:

Execution Time:

Number of Results:

UUT Result:

IT-W-7303101

NONE

lunedì 3 aprile 2023

08:49:19

ITLAVIT1

00:00:42.516

45

Terminated

Begin Sequence: MainSequence
(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\MOD\Complete_test.seq)

UUT Parameters	
Status:	Done
TestResults/Data:	
Product Name:	ARI LV
Communication Module:	RS485
UUT_info_comm	
Status:	Done
TestResults/Data:	
Product type:	ARI LV
COMM type:	COMM1_RS485
Product Firmware version:	"
COMM Firmware version:	"
General and Architecture and LED	
Status:	Skipped
Input-Output	
Status:	Skipped
Power Outage	
Status:	Skipped
Motor Driver	
Status:	Skipped

Modbus Register check	
Status:	Terminated
Module Time:	36.623

Begin Sequence: Modbus Register check
(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\MOD\Complete_test.seq)

Internal communication failure	
Status:	Done
TestResults/Data:	
Register Value:	OK
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that the remote opening via modbus worked.

Status:	Passed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that the remote closing via modbus worked.
Status:	Passed

Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that the remote closing via modbus has not worked due to closing command but for autoreclosing procedure.
Status:	Passed

End Sequence: Modbus Register check

End Sequence: MainSequence

End UUT Report

