

UUT Report

Station ID: IT-W-7303101
Serial Number: NONE
Date: mercoledì 11 gennaio 2023
Time: 09:53:01
Operator: ITLAVIT1
Execution Time: 00:00:07.927
Number of Results: 21
UUT Result: Failed
Failure Chain:

Step	Sequence	Sequence File
Numeric Limit Test - Phase Unbalance	PMD-1179	PMD-1179.seq
PMD-1179 = 4455	MainSequence	PMD-4455.seq

Begin Sequence: MainSequence
(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\M4M\PMD-4455.seq)

DUT recap	
Status:	Done
TestResults/Data:	
Serial Number:	M086AB1000
Type Designator:	M4M20SEA
FW Version:	P2.6.14.0
PMD-4455	
Status:	Skipped
PMD-1179 = 4455	
Status:	Failed
Module Time:	7.8753

Begin Sequence: PMD-1179
(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\M4M\PMD-1179.seq)

Set PhaseVoltage - LOG	
Status:	Done
TestResults/Data:	
HMI - Phase Voltage Unbalance:	429496729.5
Set Line Voltage - LOG	
Status:	Done
TestResults/Data:	
HMI - Line Voltage Unbalance:	429496729.5

Set Current - LOG	
Status:	Done
TestResults/Data:	
HMI - Current Unbalance:	429496729.5
Numeric Limit Test - Phase Unbalance	
Status:	Failed
Numeric:	-429496720.4091
Limits:	
Low:	-0.909090909090909
High:	0.909090909090909
Comparison Type:	GELE(>= <=)
Numeric Limit Test - Current Unbalance	
Status:	Failed
Numeric:	-429496689.5
Limits:	
Low:	-4
High:	4
Comparison Type:	GELE(>= <=)

End Sequence: PMD-1179

End Sequence: MainSequence

End UUT Report
