UUT Report

Station ID:	IT-W-7303101
Serial Number:	NONE
Date:	**martedì 10 ottobre 2023**
Time:	**15:31:17**
Operator:	administrator
Execution Time:	30.8425697 seconds
Number of Results:	10
UUT Result:	**Terminated**
Product:	ARI LV
Product type:	ARI LV
Comm type:	COMM1_RS485
Product FW Version:	56010804
Comm FW Version:	56010000

**Begin Sequence: MainSequence
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\Blocked MOD.seq)**

Check Lock	
Status:	Failed

Additional Results	
Status:	Done
PopupString:	Check that ARI reach Lock state after the default number of reclosing attempts.
Status:	Failed

End Sequence: MainSequence

End UUT Report