UUT Report

Station ID: IT-W-7303101

Serial Number: NONE

Date: mercoledì 1 febbraio 2023

Time: 16:34:04

Operator: ITLAVIT1

Execution Time: 00:02:09.090

Number of Results: 87

UUT Result: **Terminated**

Begin Sequence: MainSequence
(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\MOD\RS485 Modbus Communication\ARI Registers check.seq)

Internal communication failure	
Status:	Skipped
Additional Results	
Status:	Skipped
Additional Results	
Status:	Skipped
Additional Results	
Status:	Skipped
Additional Results	
Status:	Skipped
input	
Status:	Done
TestResults/Data:	
Register Value:	Disable
Pass/Fail Test	
Status:	Passed
Communication	
Status:	Done
TestResults/Data:	
Register Value:	Disable
Pass/Fail Test	
Status:	Passed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that the remote closing via input has not worked.
Status:	Passed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that the remote closing via modbus has not worked.
Status:	Passed

Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that the remote closing via input has not worked.
Status:	Passed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that the remote closing via modbus has not worked.
Status:	Passed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that the remote opening via input has not worked.
Status:	Passed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that the remote opening via modbus has not worked.
Status:	Passed
Popup PassFail	
Status:	Failed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that the remote opening via input has not worked.
Status:	Failed
Popup PassFail	
Status:	Failed

End Sequence: MainSequence

End UUT Report