UUT Report

Station ID:	IT-W-7303101
Serial Number:	NONE
Date:	martedì 14 novembre 2023
Time:	15:05:54
Operator:	administrator
Execution Time:	2239.2904518 seconds
Number of Results:	169
UUT Result:	Terminated
Product:	ARI LV
Product type:	NO COMM
Comm type:	NO COMM
Product FW Version:	NO COMM
Comm FW Version:	NO COMM

Begin Sequence: MainSequence
(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\MOD\General_test.seq)

Double_trip_ARI_blocked
Status:	Skipped

Simultaneous trip_open
Status:	Skipped

General and Architecture and LED
Status:	Skipped

Input-Output
Status:	Skipped

Power Outage
Status:	Terminated
Module Time:	2170.6431924

Begin Sequence: Power Outage
(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\MOD\General_test.seq)

Additional Results
Status:	Done
PopupString:	Check that the MOD open automatically the MPD at power On without reclosing.
Status:	Passed

Additional Results
Status:	Done
PopupString:	Check that the MOD open automatically the MPD at power On without reclosing.
Status:	Passed

Additional Results
Status:	Done
PopupString:	Check that the MOD closes automatically the MPD at power On after power fail.
Status:	Passed

Additional Results
Status:	Done
PopupString:	Check that the MOD open automatically the MPD at power On and reclose without dead time.
Status:	Passed

Check Half open	
Status:	Failed

Check Half open	
Status:	Failed

End Sequence: Power Outage

End Sequence: MainSequence

End UUT Report