UUT Report

Station ID:	IT-W-7303101
Serial Number:	NONE
Date:	**martedì 21 novembre 2023**
Time:	**16:52:18**
Operator:	administrator
Execution Time:	**56.1018345 seconds**
Number of Results:	**105**
UUT Result:	**Terminated**
Product:	**MOD LV**
Product type:	**MOD LV**
Comm type:	**COMM1_RS485**
Product FW Version:	**56010809**
Comm FW Version:	**56010000**

Begin Sequence: MainSequence
(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\MOD\FMEA.seq)

Close command and Switch1 closed - Switch2 open - before command	
Status:	Skipped

Open command and Switch1 open - Switch2 closed - before command	
Status:	Skipped

Close command and switches open - during command	
Status:	Skipped

Close command and switches closed - during command	
Status:	Skipped

Open command and switches closed	
Status:	Skipped

Open command and switches open	
Status:	Skipped

TRIP true	
Status:	Skipped

Initial state closed	
Status:	Skipped

TRIP both switches open	
Status:	Failed
Module Time:	18.6168154

Begin Sequence: TRIP both switches open
(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\MOD\FMEA.seq)

Closed - Open - Active - ON - LOG	
Status:	Done
Switch 1:	True
Swtich 2:	False

Enable Outputs LOG	
Status:	Done

Open - Open - Active - ON - LOG	
Status:	Done
Switch 1:	False

Swtich 2:	False

Disable Outputs LOG

Status:	Done

Open - Closed - Active - ON - LOG

Status:	Done
Switch 1:	False
Swtich 2:	True

Check Outputs

Status:	Failed
Configuration:	TRIP both switches open
Output_1_SIG:	True
Output_2_AUX:	False

Additional Results

Status:	Done
Configuration:	How is the status of LED?
Fix_Red:	FIX RED

Additional Results

Status:	Done
Configuration:	How is the status of MDP?
Status:	UNLOCKED

Additional Results

Status:	Done
Configuration:	Additional notes
Status:	"

End Sequence: TRIP both switches open

Initial state closed

Status:	Skipped

TRIP both switches closed

Status:	Passed
Module Time:	14.1474245

Begin Sequence: TRIP both switches closed
(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\MOD\FMEA.seq)

Closed - Open - Active - ON - LOG

Status:	Done
Switch 1:	True
Swtich 2:	False

Enable Outputs LOG

Status:	Done

Closed - Closed - Active - ON - LOG

Status:	Done
Switch 1:	True
Swtich 2:	True

Disable Outputs LOG

Status:	Done

Open - Closed - Active - ON - LOG

Status:	Done

Switch 1:	False
Swtich 2:	True

Check Outputs	
Status:	Passed
Configuration:	TRIP true
Output_1_SIG:	False
Output_2_AUX:	False

Additional Results	
Status:	Done
Configuration:	How is the status of LED?
Fix_Green:	FIX GREEN

Additional Results	
Status:	Done
Configuration:	How is the status of MDP?
Status:	UNLOCKED

Additional Results	
Status:	Done
Configuration:	Additional notes
Status:	''

End Sequence: TRIP both switches closed

Initial state closed	
Status:	Skipped

TRIP - Switch1 open - Switch2 closed	
Status:	Terminated
Module Time:	13.2181956

Begin Sequence: TRIP - Switch1 open - Switch2 closed
(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\MOD\FMEA.seq)

Open - Closed - Active - ON - LOG	
Status:	Done
Switch 1:	True
Swtich 2:	False

Enable Outputs LOG	
Status:	Done

Open - Closed - Active - ON - LOG	
Status:	Done
Switch 1:	False
Swtich 2:	True

Disable Outputs LOG	
Status:	Done

Check Outputs	
Status:	Failed
Configuration:	TRIP true
Output_1_SIG:	True
Output_2_AUX:	False

End Sequence: TRIP - Switch1 open - Switch2 closed

End Sequence: MainSequence

End UUT Report