

UUT Report

Station ID: IT-W-7303101
Serial Number: NONE
Date: martedì 21 novembre 2023
Time: 17:01:51
Operator: administrator
Execution Time: 54.2468999 seconds
Number of Results: 119
UUT Result: Terminated
Product: MOD LV
Product type: MOD LV
Comm type: COMM1_RS485
Product FW Version: 56010809
Comm FW Version: 56010000

Begin Sequence: MainSequence
(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\MOD\FMEA.seq)

Close command and Switch1 closed - Switch2 open - before command	
Status:	Skipped
Open command and Switch1 open - Switch2 closed - before command	
Status:	Skipped
Close command and switches open - during command	
Status:	Skipped
Close command and switches closed - during command	
Status:	Skipped
Open command and switches closed	
Status:	Skipped
Open command and switches open	
Status:	Skipped
TRIP true	
Status:	Skipped

Initial state closed	
Status:	Skipped

TRIP both switches open	
Status:	Failed
Module Time:	12.5358442

Begin Sequence: TRIP both switches open
(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\MOD\FMEA.seq)

Closed - Open - Active - ON - LOG	
Status:	Done
Switch 1:	True
Switch 2:	False
Enable Outputs LOG	
Status:	Done
Open - Open - Active - ON - LOG	
Status:	Done
Switch 1:	False

Switch 2:	False
Disable Outputs LOG	
Status:	Done
Open - Closed - Active - ON - LOG	
Status:	Skipped
Check Outputs	
Status:	Failed
Configuration:	TRIP both switches open
Output_1_SIG:	True
Output_2_AUX:	True

Additional Results	
Status:	Done
Configuration:	How is the status of LED?
Fix_Red:	FIX RED
Additional Results	
Status:	Done
Configuration:	How is the status of MDP?
Status:	UNLOCKED

Additional Results	
Status:	Done
Configuration:	Additional notes
Status:	"

End Sequence: TRIP both switches open

Initial state closed	
Status:	Skipped

TRIP both switches closed	
Status:	Passed
Module Time:	15.3125973

Begin Sequence: TRIP both switches closed
(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\MOD\FMEA.seq)

Closed - Open - Active - ON - LOG	
Status:	Done
Switch 1:	True
Switch 2:	False
Enable Outputs LOG	
Status:	Done
Closed - Closed - Active - ON - LOG	
Status:	Done
Switch 1:	True
Switch 2:	True
Disable Outputs LOG	
Status:	Done
Open - Closed - Active - ON - LOG	
Status:	Skipped
Check Outputs	
Status:	Passed

Configuration:	TRIP true
Output_1_SIG:	False
Output_2_AUX:	False

Additional Results	
Status:	Done
Configuration:	How is the status of LED?
Fix_Green:	FIX GREEN
Additional Results	
Status:	Done
Configuration:	How is the status of MDP?
Status:	UNLOCKED

Additional Results	
Status:	Done
Configuration:	Additional notes
Status:	"

End Sequence: TRIP both switches closed

Initial state closed	
Status:	Skipped

TRIP - Switch1 open - Switch2 closed	
Status:	Terminated
Module Time:	20.1486878

Begin Sequence: TRIP - Switch1 closed - Switch2 Open
(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\MOD\FMEA.seq)

Closed - Open - Active - ON - LOG	
Status:	Done
Switch 1:	True
Swtich 2:	False
Enable Outputs LOG	
Status:	Done
Closed - Open - Active - ON - LOG	
Status:	Done
Switch 1:	True
Swtich 2:	False
Disable Outputs LOG	
Status:	Done
Check Outputs	
Status:	Failed
Configuration:	TRIP true
Output_1_SIG:	False
Output_2_AUX:	True

Additional Results	
Status:	Done
Configuration:	How is the status of LED?
Fix_Green:	FIX GREEN
Additional Results	
Status:	Done

Configuration:	How is the status of MDP?
Status:	UNLOCKED

End Sequence: TRIP - Switch1 closed - Switch2 Open

End Sequence: MainSequence

End UUT Report
