UUT Report

Station ID: IT-W-7303101

Serial Number: NONE

Date: martedì 20 dicembre 2022

Time: 11:33:15 Operator: ITLAVIT1

Execution Time: 56.9129 seconds

Number of Results: 355 UUT Result: Passed

Begin Sequence: MainSequence

(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\Modbus RTU settings.seq)

DUT recap		
Status:	Done	
TestResults/Data:		
Serial Number:	"	
Type Designator:	B1D3MB111A	
FW Version:	0.11.0	

Pass/Fail Test		
Status:	Passed	
TestResults/Data:	'	
Address:	1	
Pass/Fail Test		
Status:	Passed	
TestResults/Data:		
Address:	2	
Pass/Fail Test		
Status:	Passed	
TestResults/Data:		
Address:	3	
Pass/Fail Test		
Status:	Passed	
TestResults/Data:		
Baud Rate:	9600	
Parity:	Even	
Pass/Fail Test		
Status:	Passed	
TestResults/Data:		
Baud Rate:	9600	
Parity:	None	
Pass/Fail Test		
Status:	Passed	
TestResults/Data:		
Baud Rate:	9600	

Parity:	Odd
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	19200
Parity:	Even
Pass/Fail Test	,
Status:	Passed
TestResults/Data:	
Baud Rate:	19200
Parity:	None
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	19200
Parity:	Odd
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	38400
Parity:	Even
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	38400
Parity:	None
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	38400
Parity:	Odd
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	57600
Parity:	Even
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	57600
Parity:	None
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	57600
Parity:	Odd
Pass/Fail Test	
Status:	Passed
TestResults/Data:	

Baud Rate:	115200	
Parity:	Even	
Pass/Fail Test		
Status:	Passed	
TestResults/Data:		
Baud Rate:	115200	
Parity:	None	
Pass/Fail Test		
Status:	Passed	
TestResults/Data:		
Baud Rate:	115200	
Parity:	Odd	

End Sequence: MainSequence

End UUT Report